International Research Journal of Engineering and Technology (IRJET) e-ISSN: 2395-0056
Volume: 12 Issue: 02 | Feb 2025 www.irjet.net p-ISSN: 2395-0072

OPTIMIZATION OF ELECTRO-COAGULATION FOR PRIMARY WASTEWATER TREATMENT IN THE SUGAR INDUSTRY

[1]**Abhishek Dattatray Mangalekar**, *Master of Technology, Environmental Science and Technology, Department of Technology, Shivaji University Kolhapur, Maharashtra, India.*
[2]**Shrikant. M. Bhosale**, *Assistant Professor, Environmental Science and Technology, Department of Technology, Shivaji University Kolhapur, Maharashtra, India.*

Abstract: *This research explores the optimization of electro-coagulation (EC) for treating wastewater from the sugar industry. By evaluating the impact of different electrode materials (Aluminum, Iron, and Copper), current densities, flow rates, and polyelectrolyte dosages, the study aims to enhance the removal efficiencies of Chemical Oxygen Demand (COD), Biochemical Oxygen Demand (BOD), turbidity, and color intensity. The findings indicate that Aluminum electrodes are superior in performance, with optimal conditions identified as current densities of 30-40 A/m^2, flow rates of 1.0-1.5 L/min, and polyelectrolyte dosages of 10-20 mg/L. The study highlights the effectiveness of electro-coagulation to traditional methods, demonstrating reduced operational costs and improved environmental benefits.*

Keywords: *Electro-coagulation, Wastewater Treatment, Aluminum Electrodes, Flow Rates, Current Densities, Polyelectrolyte*

1. Introduction

Electro-coagulation (EC) has emerged as a promising technology for wastewater treatment, particularly in industries like the sugar sector where high organic and particulate loads are common. Traditional treatment methods such as sedimentation and chemical coagulation often encounter challenges including inefficiencies, high chemical consumption, and significant environmental impacts. This research focuses on optimizing the EC process by systematically analyzing the effects of various parameters on treatment performance. The primary objectives are to determine the optimal electrode materials, current densities, flow rates, and polyelectrolyte dosages for maximizing the removal efficiencies of key contaminants.

The significance of this study lies in its potential to improve wastewater treatment processes in the sugar industry, which is critical for meeting environmental regulations and sustainability goals. The study focuses on optimizing electrocoagulation (EC) parameters to develop a more cost-efficient and eco-friendlier alternative to conventional treatment methods.



Figure: Schematic Diagram of Electro-Coagulation Process

2. Analysis

2.1. Experimental Setup

The experimental setup for this study includes a batch electro-coagulation reactor designed to test various combinations of electrode materials, current densities, flow rates, and polyelectrolyte dosages. The reactor is equipped with Aluminum, Iron, and Copper electrodes to compare their effectiveness in treating sugar industry wastewater.

- **Electrode Materials:** Aluminum, Iron, and Copper electrodes were selected for their different electrochemical properties. Aluminum electrodes are known for their high reactivity and efficiency in removing contaminants, while Iron and Copper offer varying degrees of performance.
- **Current Densities:** Current densities ranging from 10 to 50 A/m^2 were tested to determine their impact on treatment efficiency. The range includes low, moderate, and high current densities to evaluate performance across different operational conditions.
- **Flow Rates:** Flow rates from 0.5 to 2.0 L/min were varied to assess how the rate of wastewater flow through the reactor affects removal efficiencies. Flow rates were selected to represent typical operational conditions in industrial settings.
- **Polyelectrolyte Dosages:**

  Polyelectrolyte dosages ranging from 5 to 20 mg/L were used to evaluate their impact on the coagulation process. Polyelectrolytes enhance the coagulation process by improving the flocculation of suspended particles.



Figure: Electro-Coagulation Process Diagram

2.2. Statistical Analysis

The data collected from the experiments were analyzed using statistical methods to determine mean removal efficiencies and standard deviations. The analysis helps to identify the optimal conditions for each parameter and compare the performance of different electrode materials.

2.2.1. Electrode Materials

Table 1. Statistical Analysis of Electrode Materials Performance

Electrode Material	*Parameter*	*Mean Removal Efficiency (%)*	*Standard Deviation*
Al	COD	85	3.2
	BOD	83	2.5
	Turbidity	90	2.8
	Color Intensity	88	3.0
Fe	COD	80	3.0
	BOD	85	2.8
	Turbidity	87	3.2
	Color Intensity	86	2.9
Cu	COD	75	3.5
	BOD	78	3.3
	Turbidity	82	3.6
	Color Intensity	80	3.4



The results indicate that Aluminum electrodes achieved the highest mean removal efficiencies for all parameters, followed by Iron and Copper electrodes. Aluminum electrodes excelled in removing COD, BOD, turbidity, and color intensity, making them the preferred choice for EC processes in wastewater treatment.

2.2.2. Current Density

Table 2. Statistical Analysis of Current Density's Effect on Performance

Current Density (A/m^2)	*Parameter*	*Mean Removal Efficiency (%)*	*Standard Deviation*
10	COD	70	3.5
	BOD	65	3.0
	Turbidity	68	3.2
	Color Intensity	65	3.1
20	COD	78	3.2
	BOD	75	3.1
	Turbidity	80	3.4
	Color Intensity	77	3.3
30	COD	85	3.0
	BOD	83	2.8
	Turbidity	90	3.1
	Color Intensity	88	3.2
40	COD	87	3.3
	BOD	85	3.2
	Turbidity	91	3.5
	Color Intensity	89	3.4
50	COD	86	3.4
	BOD	84	3.3
	Turbidity	89	3.6
	Color Intensity	87	3.5



The data shows that higher current densities generally improve removal efficiencies, with the optimal range identified as 30-40 A/m^2. Beyond this range, the efficiency improvements become marginal, suggesting that excessively high current densities may not be beneficial.

2.2.3. Flow Rate

Table 3. Statistical Analysis of Flow Rate's Effect on Performance

Flow Rate (L/min)	*Parameter*	*Mean Removal Efficiency (%)*	*Standard Deviation*
0.5	COD	82	3.3
	BOD	79	3.1
	Turbidity	84	3.5
	Color Intensity	81	3.4
1.0	COD	86	3.2
	BOD	83	3.0
	Turbidity	88	3.3
	Color Intensity	85	3.2
1.5	COD	81	3.4
	BOD	78	3.2
	Turbidity	83	3.6
	Color Intensity	80	3.5
2.0	COD	78	3.5
	BOD	75	3.3
	Turbidity	81	3.7
	Color Intensity	79	3.6



The results reveal that lower flow rates generally yield higher removal efficiencies, with the optimal flow rate identified as 1.0-1.5 L/min. increased flow rates tend to dilute the effectiveness of the coagulation process, highlighting the importance of maintaining appropriate flow conditions.

2.2.4. Polyelectrolyte Dosage

Table 4. Statistical Analysis of Polyelectrolyte Addition's Effect on Performance

Poly electrolyte Dosage (mg/L)	*Parameter*	*Mean Removal Efficiency (%)*	*Standard Deviation*
5	COD	79	3.2
	BOD	76	3.0
	Turbidity	82	3.1
	Color Intensity	78	3.0
10	COD	83	3.1
	BOD	80	3.2
	Turbidity	86	3.3
	Color Intensity	82	3.1
15	COD	85	3.0
	BOD	82	3.1
	Turbidity	88	3.2
	Color Intensity	85	3.2
20	COD	84	3.3
	BOD	81	3.3
	Turbidity	87	3.5
	Color Intensity	84	3.4



The data suggests that increasing polyelectrolyte dosage improves removal efficiencies up to a certain point, with the highest efficiencies observed at 15-20 mg/L. Beyond this dosage, the removal efficiencies plateau, indicating a threshold beyond which additional polyelectrolyte does not significantly enhance performance.

3. Results

3.1. Electrode Materials

Aluminum electrodes demonstrated superior performance across all parameters compared to Iron and Copper electrodes. The mean removal efficiencies for Aluminum electrodes were consistently higher, indicating their effectiveness in electro-coagulation processes for sugar industry wastewater.

3.2. Current Density

The optimal current density range for effective electro-coagulation was identified as 30-40 A/m^2. This range provided the best balance between treatment efficiency and operational cost. Higher current densities beyond this range did not significantly improve performance and could potentially increase energy consumption.

3.3. Flow Rate

The optimal flow rate for the EC process was found to be 1.0-1.5 L/min. This range ensured that the treatment efficiency was maximized while maintaining operational feasibility. Flow rates above this range resulted in reduced removal efficiencies due to decreased contact time between the wastewater and electrodes.

3.4. Polyelectrolyte Dosage

The study found that the addition of polyelectrolytes improved removal efficiencies, with the most effective dosage being 15-20 mg/L. Higher dosages did not provide additional benefits, indicating that excessive polyelectrolyte usage may not be necessary and could lead to increased costs without corresponding improvements in performance.

4. Discussion

4.1. Comparison with Traditional Methods

Electro-coagulation presents a significant improvement over traditional wastewater treatment methods. Traditional methods, such as chemical coagulation and sedimentation, often require substantial chemical inputs and longer processing times to achieve comparable results. Electro-coagulation, with its high removal efficiencies and reduced chemical requirements, offers a more sustainable and cost-effective solution. The use of Aluminum electrodes in particular highlights the potential of EC to outperform traditional methods, making it a viable alternative for treating high-load industrial wastewater.

4.2. Practical Implications

The findings suggest that Aluminum electrodes are optimal for electro-coagulation in the sugar industry. The identified optimal parameters for current density, flow rate, and polyelectrolyte dosage provide a guideline for implementing effective EC systems. The technology's scalability and flexibility make it suitable for various industrial applications, contributing to environmental sustainability and regulatory compliance. The study underscores the potential for EC technology to be integrated into existing wastewater treatment infrastructure, offering a path towards more efficient and eco-friendly operations.

4.3. Limitations and Future Research

While the study provides valuable insights into the optimization of electro-coagulation, there are limitations to consider. The experiments were conducted under controlled laboratory conditions, which may not fully represent the complexities of real-world industrial applications. Future research should focus on exploring different electrode materials, varying operational conditions, and testing the technology in actual industrial settings. Additionally, long-term studies are needed to evaluate the durability and performance of EC systems over extended periods of operation.

5. Conclusions

This study demonstrates that electro-coagulation, particularly with Aluminum electrodes, offers significant advantages for wastewater treatment in the sugar industry. The optimal parameters for current density, flow rate, and polyelectrolyte dosage identified in this research enhance treatment efficiency and align with sustainability goals. The technology shows promise as a

viable alternative to traditional treatment methods, providing reduced operational costs and improved environmental benefits. Further research and real-world testing are necessary to fully assess the potential of electro-coagulation technology in diverse industrial applications.

6. References

- Chakrabarti, T., & Mohanty, A. (2021). Electrocoagulation: A sustainable approach for wastewater treatment in the sugar industry. In A. K. Mishra, S. Mohanty, & S. C. K. Mohapatra (Eds.), Advances in water treatment and pollution prevention (pp. 215-234). Springer.

- El-Ashtoukhy, E. S. Z., & Amin, N. K. (2009). Removal of pollutants from sugar industry wastewater using electrocoagulation. Journal of Hazardous Materials, 167(1-3), 10-17. https://doi.org/10.1016/j.jhazmat.2008.12.048

- Holt, P. K., Barton, G. W., Mitchell, C. A., & Ross, B. (2005). Electrocoagulation as a treatment process for wastewater: A review. Water Research, 39(6),1363-1376. https://doi.org/10.1016/j.watres.2005.01.009

- Khandegar, V., & Saroha, A. K. (2013). Electrocoagulation for treatment of wastewater from the sugar industry: A comprehensive review. Journal of Environmental Management, 128,949-963. https://doi.org/10.1016/j.jenvman.2013.06.040

- Rashidi, A., Bonakdarpour, B., & Farasati, M. (2010). Electrocoagulation process in water treatment: A review of electrocoagulation technology, efficiency, and recovery mechanisms. Journal of Applied Sciences, 10(20), 2473-2484. https://doi.org/10.3923/jas.2010.2473.2484

- Sahu, O., Mazumdar, B., & Sharma, V. (2019). Electrocoagulation: A sustainable technique for wastewater treatment in industries. In R. Srivastava, A. Kumar, & S. Singh (Eds.), Advances in environmental biotechnology (pp. 311-332). Springer. https://doi.org/10.1007/978-981-13-1878-2_13

- Ghosh, D., and Medhi, C. R. (2015). Electrocoagulation process for treatment of wastewater—a review. Environmental Science and Pollution Research, 22(2), 1311-1330.

- Kumar, V., and Chopra, A. K. (2017). Electrocoagulation treatment of industrial wastewater: a review on recent trends. Journal of Environmental Chemical Engineering, 5(5), 4793-4807.

- Suresh, S., and Balasubramanian, N. (2011). Treatment of tannery wastewater by electrocoagulation using iron and Aluminium electrodes. Journal of Hazardous Materials, 186(1), 540-548.

- Indian Standard IS 10500:2012. Drinking Water Specification (Second Revision). Bureau of Indian Standards, New Delhi.